



COIL TYPE GROUND
 GROUND WIRE TO BE LOCATED ON SAME SIDE AS NEUTRAL CONDUCTOR AND IN QUADRENT OPPOSITE CLIMBING SPACE OR POLE TOP PIN. STAPLES ON GROUND WIRE SHALL BE 2'-0" APART EXCEPT FOR A DISTANCE AT 8'-0" ABOVE GROUND AND 8'-0" FROM TOP OF POLE WHERE THEY SHALL BE 6" APART. GROUND WIRE TO CLEAR ALL HARDWARE BY 2" MIN. AND SHALL BE STAPLED TO MAINTAIN THIS POSITION.

DRAWN BY:	DATE:	APPROVED BY:
		CP
REVISED BY:	DATE:	APPROVED BY:

TITLE:
 POLE GROUND DETAIL

GARLAND
 POWER & LIGHT

STANDARD NO.:
 OH-915