



NOTE:
ENGINEERING TO SPECIFY
PROPER WEDGE CONNECTORS

TITLE:

1200 KVAR CAPACITOR BANK
PRE-ASSEMBLE W/VACUUM
SWITCHES & SURGE ARRESTORS

GARLAND
POWER & LIGHT

STANDARD NO.:

OH-985

DRAWN BY: CY/JC	DATE: 10/19/17	APPROVED BY: DM
--------------------	-------------------	--------------------

REVISED BY:	DATE:	APPROVED BY:
-------------	-------	--------------

Construction Standard No.

OH-985

Title: 1200 KVAR CAPACITOR BANK - PRE-ASSEMBLED

Rev. Date: 3/25/2014

Pic #	Description	IBM NO.	Qty
1	CAPACITOR CLUSTER 1200 KVAR SIX 200S IN-LINE 7200/12470	286-12-10830	1
2	BOLT MACHINE 3/4" X 14" W/NUT	285-08-10814	2
3	WASHER SQUARE 3/4" 250/BX	285-08-15315	2
4	WASHER SPRING DOUBLE COIL 3/4" 500/BX	285-08-85425	2
5	CUTOUT 100 AMP 15KV	286-19-10250	3
6	CABLE, 5 KV # 2 AWG OKO GUARD	280-42-50005	20'
7	CONDUIT RIGID 1" GALV 10' LENGTH	285-14-14070	3
8	STRAP 1" 2 HOLE RIGID - NON STOCK ITEM	000-00-00035	5
9	60 AMP ROUND METER BASE - NON STOCK ITEM	000-00-00039	1
10	CONTROLLER TEMPERATURE FOR CAPACITOR BANKS	286-81-10330	1
11	# 2 CU BARE HD 7 STR	280-09-21051	8'
12	ROD GROUNDING 5/8" X 8'	285-36-15108	1
13	CLAMP GROUND ROD 5/8"	285-13-16025	1
14	3" ALUMINUM NUMBERS - TOOL ROOM ITEM	000-00-00018	3

Garland Power & Light



OH-985