



****ENGINEERING NOTES:**

- NEUTRAL MAY BE INSTALLED AT 60" TO MEET EXISTING FIELD CONDITIONS.

TITLE:

DUAL PHASE INLINE
ON WOOD

GARLAND
POWER & LIGHT

STANDARD NO.:

OH-1300

DRAWN BY: CY/JC	DATE: 11/02/17	APPROVED BY: DM
REVISED BY:	DATE:	APPROVED BY:

Construction Standard No.

OH-1300

Title: DUAL PHASE INLINE ON WOOD

Rev. Date: 10/13/2017

Pic #	Description	IBM NO.	Qty
1	CROSSARM WOOD TREATED 3-3/4" X 4-3/4" X 8', 4 PIN	535-18-10043	1
2	BOLT MACHINE 5/8" X 16" W/NUT	285-08-10790	1
3	WASHER SQUARE 5/8" 250/BX	285-08-15320	5
4	WASHER SPRING DOUBLE COIL 5/8" 500/BX	285-08-85430	5
5	BRACE CROSSARM WOOD 60" SPAN	285-10-11125	1
6	BOLT MACHINE 1/2" X 6" W/NUT 100/BX	285-08-10730	2
7	WASHER SQUARE 1/2" 500/BX	285-08-15310	2
8	WASHER DOUBLE COIL 1/2" CHANCE C205-0185 1500/BX	285-08-85420	2
9	BOLT MACHINE 5/8" X 14" W/NUT	285-08-10788	2
10	INSULATOR PIN TYPE 15KV	286-42-25100	2
11	PIN STEEL 5/8" X 5-3/4" W/NUTS	285-39-10246	2
12	1 PT RACK GALV 1-1/2" X 1/2" X 1/8" CLEVIS	285-39-14039	1
13	INSULATOR SPOOL TYPE SECONDARY	286-42-23310	1

Garland Power & Light



OH-1300