



GENERAL CONSTRUCTION NOTE:

1. STANDARD 5/8" SQUARE NUTS ISSUED WITH DA BOLTS, OE BOLTS, MH BOLTS AND STEEL INSULATOR PINS SHOULD BE USED FOR LOCK (JAM) NUTS.
2. DISCARD SQUARE WASHER AND LOCK (MF) NUT ISSUED WITH STEEL INSULATOR PIN, USE ISSUED NUT WASHER IN PLACE OF SQUARE WASHER.

TITLE:

DUAL PHASE DEADEND  
ON WOOD

**GARLAND**  
POWER & LIGHT

STANDARD NO.:

OH-1310

DRAWN BY: GL	DATE: 5/19/04	APPROVED BY: CP
REVISED BY:	DATE:	APPROVED BY:

**CONSTRUCTION STANDARD NO. : OH-1310****TITLE: TWO PHASE DEAD END ON WOOD**

REV. DATE: 5/21/2002

PIC. #	DESCRIPTION	IBM NO.	QTY.
1	CROSSARM WOOD TREATED 3-3/4" X 4-3/4" X 8', 4 PIN	535-18-10043	2
2	BRACE CROSSARM WOOD 60" SPAN	285-10-11125	2
3	INSULATOR SPOOL TYPE SECONDARY	286-42-23310	1
4	1 PT RACK GALV 1-1/2" X 1/2" X 1/8" CLEVIS	285-39-14039	1
5	INSULATOR DEAD END 3.5" X 12-1/2" LENGTH CHANCE #C654-3015	286-42-26020	2
6	WASHER GALV TAP FLG 1/2"	285-08-85400	4
7	BOLT WASHER HEAD 1/2" X 6" W/ WASHER NUT	285-08-96910	4
8	BOLT DOUBLE ARMING 5/8" X 22"	285-08-21560	3
9	NUT 5/8" OVAL EYE	285-08-56640	2
10	BOLT DOUBLE ARMING 5/8" X 14"	285-08-21552	1
11	BOLT MACHINE 5/8" X 12" W/NUT	285-08-10786	1
12	CLAMP DEADEND STRAIGHT LINE ALUM ACSR .470" TO .198", 2/O TO #6	285-13-16395	2
13	NUT WASHER 5/8" THREAD JOSLYN	285-08-14674	13