



GENERAL CONSTRUCTION NOTE:

1. STANDARD 5/8" SQUARE NUTS ISSUED WITH DA BOLTS, OE BOLTS, MH BOLTS AND STEEL INSULATOR PINS SHOULD BE USED FOR LOCK (JAM) NUTS.
2. DISCARD SQUARE WASHER AND LOCK (MF) NUT ISSUED WITH STEEL INSULATOR PIN, USE ISSUED NUT WASHER IN PLACE OF SQUARE WASHER.

DRAWN BY:	DATE:	APPROVED BY:
GL	5/19/04	CP
REVISED BY:	DATE:	APPROVED BY:

TITLE:

DUAL PHASE DOUBLE
DEAD END ON WOOD

GARLAND
POWER & LIGHT

STANDARD NO.:

OH-1315

CONSTRUCTION STANDARD NO. : OH-1315**TITLE: TWO PHASE DBL DEAD END ON WOOD**

REV. DATE: 5/21/2002

PIC. #	DESCRIPTION	IBM NO.	QTY.
1	CROSSARM WOOD TREATED 3-3/4" X 4-3/4" X 8', 4 PIN	535-18-10043	2
2	BRACE CROSSARM WOOD 60" SPAN	285-10-11125	2
3	1 PT RACK GALV 1-1/2" X 1/2" X 1/8" CLEVIS	285-39-14039	2
4	INSULATOR SPOOL TYPE SECONDARY	286-42-23310	2
5	INSULATOR PIN TYPE 15KV	286-42-25100	4
6	PIN STEEL 5/8" X 5-3/4" W/NUTS	285-39-10246	4
7	INSULATOR DEAD END 3.5" X 12-1/2" LENGTH CHANCE #C654-3015	286-42-26020	4
8	WASHER GALV TAP FLG 1/2"	285-08-85400	4
9	BOLT WASHER HEAD 1/2" X 6" W/ WASHER NUT	285-08-96910	4
10	BOLT DOUBLE ARMING 5/8" X 14"	285-08-21552	1
11	BOLT DOUBLE ARMING 5/8" X 22"	285-08-21560	3
12	NUT 5/8" OVAL EYE	285-08-56640	4
13	NUT WASHER 5/8" THREAD JOSLYN	285-08-14674	17
14	CLAMP DEADEND STRAIGHT LINE ALUM ACSR .470" TO .198", 2/O TO #6	285-13-16395	4
15	BOLT MACHINE 5/8" X 12" W/NUT	285-08-10786	1