



GENERAL CONSTRUCTION NOTE:

1. STANDARD 5/8" SQUARE NUTS ISSUED WITH DA BOLTS, OE BOLTS, MH BOLTS AND STEEL INSULATOR PINS SHOULD BE USED FOR LOCK (JAM) NUTS.
2. DISCARD SQUARE WASHER AND LOCK (MF) NUT ISSUED WITH STEEL INSULATOR PIN, USE ISSUED NUT WASHER IN PLACE OF SQUARE WASHER.

TITLE:

DUAL PHASE INLINE  
ON FIBERGLASS

**GARLAND**  
POWER & LIGHT

STANDARD NO.:

OH-1400

DRAWN BY: LG	DATE: 3/17/04	APPROVED BY: CP
REVISED BY:	DATE:	APPROVED BY:

**CONSTRUCTION STANDARD NO. : OH-1400****TITLE: TWO PHASE INLINE ON FIBERGLASS**

REV. DATE: 5/21/2002

PIC. #	DESCRIPTION	IBM NO.	QTY.
1	ARM FIBERGLASS 21" BRACKET CUT OUT AND ARRESTOR	285-21-13776	2
2	INSULATOR PIN TYPE 15KV	286-42-25100	2
3	INSULATOR SPOOL TYPE SECONDARY	286-42-23310	1
4	1 PT RACK GALV 1-1/2" X 1/2" X 1/8" CLEVIS	285-39-14039	1
5	BOLT MACHINE 5/8" X 12" W/NUT	285-08-10786	1
6	BOLT DOUBLE ARMING 5/8" X 14"	285-08-21552	1
7	BOLT DOUBLE ARMING EYE 5/8" X 16"	285-08-21553	1
8	PIN,INSULATOR, STEEL, 5/8"X1 1/2" SHANK JOSLYN # J221 (E)	285-39-10260	2
9	NUT WASHER 5/8" THREAD JOSLYN	285-08-14674	7