



GENERAL CONSTRUCTION NOTE:

- 1 DISCARD LOCK (MF) NUT WITH ISSUED WITH STEEL INSULATOR PIN.

ENGINEERING NOTE:

- 1 LIGHTNING ARRESTOR POSITION WHEN USED WITHOUT TRANSFORMER (OH-30002)
- 2. LIGHTNING ARRESTOR AND GROUND ROD TO BE SPECIFIED BY ENGINEER

TITLE:

TWO PHASE DEAD
END ON 8' FIBER ARM

GARLAN
POWER & LIGHT

STANDARD NO.

OH-1411

DRAWN BY: JC	DATE: 6-16-09	APPROVED BY:
REVISED BY: CY/JC	DATE: 6-16-09	APPROVED BY:

CONSTRUCTION STANDARD NO. : OH-1411**TITLE: TWO PHASE DEAD END ON 8' FIBER ARM**

REV. DATE: 11/17/2009

PIC. #	DESCRIPTION	IBM NO.	QTY.
1	CROSSARM, 8' DEADEND LIGHT DUTY LEWTEX	285-22-25340	1
2	INSULATOR DEAD END 3.5" X 12-1/2" LENGTH CHANGE #C654-3015	286-42-26020	2
3	INSULATOR SPOOL TYPE SECONDARY	286-42-23310	1
4	1 PT RACK GALV 1-1/2" X 1/2" X 1/8" CLEVIS	285-39-14039	1
5	BOLT MACHINE 5/8" X 12" W/NUT	285-08-10786	1
6	CLAMP DEADEND STRAIGHT LINE ALUM ACSR .470" TO .198", 2/O TO #6	285-13-16395	2
7	WASHER SPRING DOUBLE COIL 5/8" 500/BX	285-08-85430	3
8	BOLT MACHINE 5/8" X 14" W/NUT	285-08-10788	2
9	WASHER SQUARE 5/8" 250/BX	285-08-15320	3