



TITLE:

DUAL PHASE DOUBLE  
DEAD END ON  
5' FIBER ARM

**GARLAND**  
POWER & LIGHT

STANDARD NO.:

OH-1415

DRAWN BY: CY/JC	DATE: 10/19/17	APPROVED BY: DM
--------------------	-------------------	--------------------

REVISED BY:	DATE:	APPROVED BY:
-------------	-------	--------------

# Construction Standard No.

# OH-1415

Title: DUAL PHASE DOUBLE DEADEND ON 5' FIBER ARM

Rev. Date: 10/10/2017

Pic #	Description	IBM NO.	Qty
1	CROSSARM, 60" x 3" FIBERGLASS (FOR DEAD ENDING CONDUCTORS)	285-21-13755	1
2	BOLT MACHINE 5/8" X 14" W/NUT	285-08-10788	2
3	WASHER SQUARE 5/8" 250/BX	285-08-15320	4
4	WASHER SPRING DOUBLE COIL 5/8" 500/BX	285-08-85430	5
5	INSULATOR PIN TYPE 15KV	286-42-25100	2
6	PIN STEEL 5/8" X 5-3/4" W/NUTS	285-39-10246	2
7	INSULATOR DEAD END 3.5" X 12-1/2" LENGTH CHANCE #C654-3015	286-42-26020	4
8	CLAMP DEADEND STRAIGHT LINE ALUM ACSR .470" TO .198", 2/O TO #6	285-13-16395	4
9	BOLT DOUBLE ARMING 5/8" X 14"	285-08-21552	1
10	1 PT RACK GALV 1-1/2" X 1/2" X 1/8" CLEVIS	285-39-14039	2
11	INSULATOR SPOOL TYPE SECONDARY	286-42-23310	2

