



GENERAL CONSTRUCTION NOTE:

1. STANDARD 5/8" SQUARE NUTS ISSUED WITH DA BOLTS, MH BOLTS AND STEEL INSULATOR PINS SHOULD BE USED FOR LOCK (JAM) NUTS.
2. DISCARD SQUARE WASHER AND LOCK (MF) NUT ISSUED WITH STEEL INSULATOR PIN, USE ISSUED NUT WASHER IN PLACE OF SQUARE WASHER.

DRAWN BY: JC	DATE: 6-16-09	APPROVED BY:
REVISED BY: CY/JC	DATE: 6-16-09	APPROVED BY:

TITLE:
TWO PHASE DOUBLE
DEAD END ON 8'
FIBER ARM

GARLAN
POWER & LIGHT

STANDARD NO.
OH-1416

CONSTRUCTION STANDARD NO. : OH-1416

TITLE: TWO PHASE DBL DEAD END ON 8' FIBER ARM

REV. DATE: 11/17/2009

PIC. #	DESCRIPTION	IBM NO.	QTY.
1	CROSSARM, 8' DEADEND LIGHT DUTY LEWTEX	285-22-25340	1
2	INSULATOR DEAD END 3.5" X 12-1/2" LENGTH CHANCE #C654-3015	286-42-26020	4
3	INSULATOR SPOOL TYPE SECONDARY	286-42-23310	2
4	1 PT RACK GALV 1-1/2" X 1/2" X 1/8" CLEVIS	285-39-14039	2
5	BOLT DOUBLE ARMING 5/8" X 14"	285-08-21552	1
6	CLAMP DEADEND STRAIGHT LINE ALUM ACSR .470" TO .198", 2/O TO #6	285-13-16395	4
7	BOLT MACHINE 5/8" X 14" W/NUT	285-08-10788	2
8	WASHER SPRING DOUBLE COIL 5/8" 500/BX	285-08-85430	4
9	PIN STEEL 5/8" X 5-3/4" W/NUTS	285-39-10246	2
10	INSULATOR PIN TYPE 15KV	286-42-25100	2
11	WASHER SQUARE 5/8" 250/BX	285-08-15320	4