



GENERAL CONSTRUCTION NOTE:

1. STANDARD 5/8" SQUARE NUTS ISSUED WITH DA BOLTS, OE BOLTS, MH BOLTS AND STEEL INSULATOR PINS SHOULD BE USED FOR LOCK (JAM) NUTS.
2. DISCARD SQUARE WASHER AND LOCK (MF) NUT ISSUED WITH STEEL INSULATOR PIN, USE ISSUED NUT WASHER IN PLACE OF SQUARE WASHER.

A	#6-4/0 REG ARM
B	336/477 HD ARM
C	336/477 REG ARM
L	FOR USE WITH OH-940

DRAWN BY: GL	DATE: 8/24/04	APPROVED BY: CP
REVISED BY:	DATE:	APPROVED BY:

TITLE:
**THREE PHASE DOUBLE
 DEAD END ON WOOD**

GARLAND
 POWER & LIGHT

STANDARD NO.:
 OH-1515

CONSTRUCTION STANDARD NO. : OH-1515B**TITLE: 3 PHASE DOUBLE DEAD END ON WOOD 336-477**

REV. DATE: 5/21/2002

PIC. #	DESCRIPTION	IBM NO.	QTY.
1	CROSSARM WOOD TREATED 4-3/4" X 5-3/4" X 8', 4 PIN	535-18-10050	2
2	BRACE CROSSARM WOOD 60" SPAN	285-10-11125	2
5	INSULATOR PIN TYPE 15KV	286-42-25100	6
6	PIN STEEL 5/8" X 6-1/2" W/NUTS	285-39-10241	6
7	INSULATOR DEAD END 3.5" X 12-1/2" LENGTH CHANCE #C654-3015	286-42-26020	6
8	BOLT WASHER HEAD 1/2" X 8" W/ WASHER NUT	285-08-96914	4
9	WASHER GALV TAP FLG 1/2"	285-08-85400	4
10	BOLT DOUBLE ARMING 5/8" X 14"	285-08-21552	2
11	BOLT DOUBLE ARMING 5/8" X 22"	285-08-21560	3
12	NUT 5/8" OVAL EYE	285-08-56640	8
13	CLAMP DEADEND STRAIGHT LINE .464" TO .860"	285-13-16390	8
14	NUT WASHER 5/8" THREAD JOSLYN	285-08-14674	14

CONSTRUCTION STANDARD NO. : OH-1515A**TITLE: 3 PHASE DOUBLE DEAD END ON WOOD 6-4/0****REV. DATE: 5/21/2002**

PIC. #	DESCRIPTION	IBM NO.	QTY.
1	CROSSARM WOOD TREATED 3-3/4" X 4-3/4" X 8', 4 PIN	535-18-10043	2
2	BRACE CROSSARM WOOD 60" SPAN	285-10-11125	2
3	INSULATOR SPOOL TYPE SECONDARY	286-42-23310	2
4	1 PT RACK GALV 1-1/2" X 1/2" X 1/8" CLEVIS	285-39-14039	2
5	INSULATOR PIN TYPE 15KV	286-42-25100	6
6	PIN STEEL 5/8" X 5-3/4" W/NUTS	285-39-10246	6
7	INSULATOR DEAD END 3.5" X 12-1/2" LENGTH CHANCE #C654-3015	286-42-26020	6
8	BOLT WASHER HEAD 1/2" X 6" W/ WASHER NUT	285-08-96910	4
9	WASHER GALV TAP FLG 1/2"	285-08-85400	4
10	BOLT DOUBLE ARMING 5/8" X 14"	285-08-21552	2
11	BOLT DOUBLE ARMING 5/8" X 22"	285-08-21560	3
12	NUT 5/8" OVAL EYE	285-08-56640	6
13	CLAMP DEADEND STRAIGHT LINE ALUM ACSR .470" TO .198", 2/O TO #6	285-13-16395	6
14	NUT WASHER 5/8" THREAD JOSLYN	285-08-14674	14

CONSTRUCTION STANDARD NO. : OH-1515C**TITLE: 3 PHASE DOUBLE DEAD END ON WOOD 336-477 SM ARM****REV. DATE: 5/21/2002**

PIC. #	DESCRIPTION	IBM NO.	QTY.
1	CROSSARM WOOD TREATED 3-3/4" X 4-3/4" X 8', 4 PIN	535-18-10043	2
2	BRACE CROSSARM WOOD 60" SPAN	285-10-11125	2
5	INSULATOR PIN TYPE 15KV	286-42-25100	6
6	PIN STEEL 5/8" X 5-3/4" W/NUTS	285-39-10246	6
7	INSULATOR DEAD END 3.5" X 12-1/2" LENGTH CHANCE #C654-3015	286-42-26020	6
8	BOLT WASHER HEAD 1/2" X 6" W/ WASHER NUT	285-08-96910	4
9	WASHER GALV TAP FLG 1/2"	285-08-85400	4
10	BOLT DOUBLE ARMING 5/8" X 14"	285-08-21552	2
11	BOLT DOUBLE ARMING 5/8" X 22"	285-08-21560	3
12	NUT 5/8" OVAL EYE	285-08-56640	8
13	CLAMP DEADEND STRAIGHT LINE .464" TO .860"	285-13-16390	8
14	NUT WASHER 5/8" THREAD JOSLYN	285-08-14674	14