

TITLE:

THREE PHASE DEADEND  
SLACKSPAN ON WOOD

**GARLAND**  
POWER & LIGHT

STANDARD NO.:









OH-1565

DRAWN BY:	DATE:	APPROVED BY:
GL	8/24/04	CP

REVISED BY:	DATE:	APPROVED BY:

**CONSTRUCTION STANDARD NO. : OH-1565A****TITLE: 3 PHASE D.E. SLACK SPAN ON WOOD 6-4/0**

REV. DATE: 9/30/2004

PIC. #	DESCRIPTION	IBM NO.	QTY.
1	CROSSARM WOOD TREATED 3-3/4" X 4-3/4" X 8', 4 PIN	535-18-10043	2
2	BRACE CROSSARM WOOD 60" SPAN	285-10-11125	2
3	INSULATOR SPOOL TYPE SECONDARY	286-42-23310	2
4	1 PT RACK GALV 1-1/2" X 1/2" X 1/8" CLEVIS	285-39-14039	2
5	INSULATOR PIN TYPE 15KV	286-42-25100	6
6	PIN STEEL 5/8" X 5-3/4" W/NUTS	285-39-10246	6
7	INSULATOR DEAD END 3.5" X 12-1/2" LENGTH CHANCE #C654-3015	286-42-26020	3
8	BOLT WASHER HEAD 1/2" X 6" W/ WASHER NUT 	285-08-96910 	4
9	WASHER GALV TAP FLG 1/2" 	285-08-85400 	4
10	BOLT DOUBLE ARMING 5/8" X 22"	285-08-21560	3
11	BOLT DOUBLE ARMING 5/8" X 14"	285-08-21552	1
12	BOLT WASHER HEAD 5/8" X 14" W/ WASHER NUT 	285-08-96926 	2
13	CLAMP DEADEND STRAIGHT LINE ALUM ACSR .470" TO .198", 2/O TO #6	285-13-16395	3
14	NUT 5/8" OVAL EYE	285-08-56640	3
15	NUT WASHER 5/8" THREAD JOSLYN 	285-08-14674 	14



**CONSTRUCTION STANDARD NO. : OH-1565B****TITLE: 3 PHASE D.E. SLACK SPAN ON WOOD 336-477 - FOR  
REMOVAL ONLY**

REV. DATE: 9/30/2004

**Total Material Cost : \$255.24**

PIC. #	DESCRIPTION	IBM NO.	QTY.
0	BOLT DOUBLE ARMING 5/8" X 14"	285-08-21552	1
0	BOLT DOUBLE ARMING 5/8" X 22"	285-08-21560	3
0	NUT 5/8" OVAL EYE	285-08-56640	3
0	WASHER GALV TAP FLG 1/2"	285-08-85400	4
0	BOLT WASHER HEAD 1/2" X 8" W/ WASHER NUT	285-08-96914	4
0	BOLT WASHER HEAD 5/8" X 14" W/ WASHER NUT	285-08-96926	2
0	BRACE CROSSARM WOOD 60" SPAN	285-10-11125	2
0	CLAMP DEADEND STRAIGHT LINE .464" TO .860"	285-13-16390	3
0	PIN STEEL 5/8" X 5-3/4" W/NUTS	285-39-10246	6
0	1 PT RACK GALV 1-1/2" X 1/2" X 1/8" CLEVIS	285-39-14039	2
0	INSULATOR SPOOL TYPE SECONDARY	286-42-23310	2
0	INSULATOR PIN TYPE 15KV	286-42-25100	6
0	INSULATOR DEAD END 3.5" X 12-1/2" LENGTH CHANCE #C654-3015	286-42-26020	3
0	CROSSARM WOOD TREATED 4-3/4" X 5-3/4" X 8', 4 PIN	535-18-10050	2