



A	#6-4/0
B	336/477 FOR REMOVAL ONLY

DRAWN BY:	DATE:	APPROVED BY:
GL	5/19/04	CP
REVISED BY:	DATE:	APPROVED BY:

TITLE:
 THREE PHASE DEAD
 END SLACKSPAN ON
 5' FIBER ARM

GARLAND
 POWER & LIGHT
 STANDARD NO.:
 OH-1646

CONSTRUCTION STANDARD NO. : OH-1646A**TITLE: 3 PH DE SLACK SPAN ON 5' FIBER ARM 6-4/0**

REV. DATE: 12/4/2003

PIC. #	DESCRIPTION	IBM NO.	QTY.
1	CROSSARM, 60" x 3" FIBERGLASS (FOR DEAD ENDING CONDUCTORS)	285-21-13755	1
2	PIN POLE TOP, FIBERGLASS, CONTINENTAL GRP-58M-21, 1" THRDS	285-21-13825	1
3	INSULATOR DEAD END 3.5" X 12-1/2" LENGTH CHANCE #C654-3015	286-42-26020	3
4	INSULATOR PIN TYPE 15KV	286-42-25100	3
5	PIN STEEL 5/8" X 5-3/4" W/NUTS	285-39-10246	2
6	INSULATOR SPOOL TYPE SECONDARY	286-42-23310	2
7	1 PT RACK GALV 1-1/2" X 1/2" X 1/8" CLEVIS	285-39-14039	2
8	BOLT WASHER HEAD 5/8" X 14" W/ WASHER NUT	285-08-96926	3
9	BOLT DOUBLE ARMING 5/8" X 20"	285-08-21558	1
10	NUT 5/8" OVAL EYE	285-08-56640	1
11	CLAMP DEADEND STRAIGHT LINE ALUM ACSR .470" TO .198", 2/O TO #6	285-13-16395	3
12	NUT WASHER 5/8" THREAD JOSLYN	285-08-14674	5