



GENERAL CONSTRUCTION NOTE:

1. STANDARD 5/8" SQUARE NUTS ISSUED WITH DA BOLTS, MH BOLTS AND STEEL INSULATOR PINS SHOULD BE USED FOR LOCK (JAM) NUTS.
2. DISCARD SQUARE WASHER AND LOCK (MF) NUT ISSUED WITH STEEL INSULATOR PIN, USE ISSUED NUT WASHER IN PLACE OF SQUARE WASHER.

A	8' CROSSARM
B	10' CROSSARM

DRAWN BY: GL	DATE: 8/3/04	APPROVED BY: CP
REVISED BY:	DATE:	APPROVED BY:

TITLE:

THREE PHASE DOUBLE
DEAD END ON
FIBER ARM

GARLAND
POWER & LIGHT

STANDARD NO.:

OH-1656

CONSTRUCTION STANDARD NO. : OH-1656A**TITLE: THREE PHASE DDE 8' FIBERGLASS CROSSARM**

REV. DATE: 10/1/2004

PIC. #	DESCRIPTION	IBM NO.	QTY.
1	CROSSARM, 8' FIBERGLASS DEADEND (GRAY IN COLOR)	285-22-25350	1
2	NUT 5/8" OVAL EYE	285-08-56640	2
3	INSULATOR DEAD END 3.5" X 12-1/2" LENGTH CHANCE #C654-3015	286-42-26020	6
4	CLAMP DEADEND STRAIGHT LINE .464" TO .860"	285-13-16390	8
5	BOLT DOUBLE ARMING 5/8" X 14"	285-08-21552	1
6	BOLT MACHINE 3/4" X 12" W/NUT	285-08-10812	2
7	NUT 3/4" OVAL EYE	285-08-56642	2
8	NUT WASHER 5/8" THREAD JOSLYN	285-08-14674	2
9	NUT WASHER 3/4"	285-08-74676	3
10	PIN STEEL 5/8" X 5-3/4" W/NUTS	285-39-10246	3
11	INSULATOR PIN TYPE 15KV	286-42-25100	3

CONSTRUCTION STANDARD NO. : OH-1656B**TITLE: THREE PHASE DDE 10' FIBERGLASS CROSSARM**

REV. DATE: 10/1/2004

PIC. #	DESCRIPTION	IBM NO.	QTY.
1	CROSSARM, 10' FIBERGLASS DDE HEAVY DUTY LEWTEX	285-22-25400	1
2	NUT 5/8" OVAL EYE	285-08-56640	2
3	INSULATOR DEAD END 3.5" X 12-1/2" LENGTH CHANCE #C654-3015	286-42-26020	6
4	CLAMP DEADEND STRAIGHT LINE .464" TO .860"	285-13-16390	8
5	BOLT DOUBLE ARMING 5/8" X 14"	285-08-21552	1
6	BOLT MACHINE 3/4" X 12" W/NUT	285-08-10812	2
7	NUT 3/4" OVAL EYE	285-08-56642	2
8	NUT WASHER 5/8" THREAD JOSLYN	285-08-14674	2
9	NUT WASHER 3/4"	285-08-74676	3
10	PIN STEEL 5/8" X 5-3/4" W/NUTS	285-39-10246	3
11	INSULATOR PIN TYPE 15KV	286-42-25100	3