



GENERAL CONSTRUCTION NOTE:

1. STANDARD 5/8" SQUARE NUTS ISSUED WITH DA BOLTS, MH BOLTS AND STEEL INSULATOR PINS SHOULD BE USED FOR LOCK (JAM) NUTS.
2. DISCARD SQUARE WASHER AND LOCK (MF) NUT ISSUED WITH STEEL INSULATOR PIN, USE ISSUED NUT WASHER IN PLACE OF SQUARE WASHER

DRAWN BY:	DATE	APPROVED BY:
JC	6-16-09	
REVISED BY:	DATE:	APPROVED BY:
CY/JC	6-16-09	

TITLE:

THREE PHASE SMALL  
WIRE DOUBLE  
DEAD END ON 8'  
FIBER ARM

**GARLAN**  
POWER & LIGHT

STANDARD NO.

OH-1657

**CONSTRUCTION STANDARD NO. : OH-1657****TITLE: THREE PHASE SMALL WIRE DDE 8' FIBERGLASS  
CROSSARM**

REV. DATE: 11/17/2009

PIC. #	DESCRIPTION	IBM NO.	QTY.
1	CROSSARM, 8' DEADEND LIGHT DUTY LEWTEX	285-22-25340	1
2	NUT 5/8" OVAL EYE	285-08-56640	2
3	INSULATOR DEAD END 3.5" X 12-1/2" LENGTH CHANCE #C654-3015	286-42-26020	6
4	CLAMP DEADEND STRAIGHT LINE ALUM ACSR .470" TO .198", 2/O TO #6	285-13-16395	6
5	BOLT DOUBLE ARMING 5/8" X 14"	285-08-21552	2
6	WASHER SQUARE 5/8" 250/BX	285-08-15320	8
7	WASHER SPRING DOUBLE COIL 5/8" 500/BX	285-08-85430	8
8	PIN STEEL 5/8" X 5-3/4" W/NUTS	285-39-10246	3
9	INSULATOR PIN TYPE 15KV	286-42-25100	3
10	INSULATOR SPOOL TYPE SECONDARY	286-42-23310	2
11	1 PT RACK GALV 1-1/2" X 1/2" X 1/8" CLEVIS	285-39-14039	2
12	BOLT MACHINE 5/8" X 14" W/NUT	285-08-10788	1