



A	#6 - 4/0
B	336/477

TITLE:

THREE PHASE VERTICAL
DOUBLE DEADEND

GARLAND
POWER & LIGHT

DRAWN BY: GL	DATE: 10/27/04	APPROVED BY: CP
------------------------	--------------------------	---------------------------

REVISED BY:	DATE:	APPROVED BY:
-------------	-------	--------------

STANDARD NO.:

OH-1660

CONSTRUCTION STANDARD NO. : OH-1660A

TITLE: VERTICAL DOUBLE DEAD END 6-4/0

REV. DATE: 5/21/2002

PIC. #	DESCRIPTION	IBM NO.	QTY.
1	INSULATOR DEAD END 3.5" X 12-1/2" LENGTH CHANCE #C654-3015	286-42-26020	6
2	INSULATOR SPOOL TYPE SECONDARY	286-42-23310	2
3	1 PT RACK GALV 1-1/2" X 1/2" X 1/8" CLEVIS	285-39-14039	2
4	BOLT OVAL EYE 5/8" X 14" W/NUT	285-08-58860	6
5	BOLT WASHER HEAD 5/8" X 14" W/ WASHER NUT	285-08-96926	2
6	CLAMP DEADEND STRAIGHT LINE ALUM ACSR .470" TO .198", 2/O TO #6	285-13-16395	6
7	NUT WASHER 5/8" THREAD JOSLYN	285-08-14674	8

CONSTRUCTION STANDARD NO. : OH-1660B

TITLE: VERTICAL DOUBLE DEAD END 336-477

REV. DATE: 5/21/2002

PIC. #	DESCRIPTION	IBM NO.	QTY.
1	INSULATOR DEAD END 3.5" X 12-1/2" LENGTH CHANCE #C654-3015	286-42-26020	6
4	BOLT OVAL EYE 5/8" X 14" W/NUT	285-08-58860	8
6	CLAMP DEADEND STRAIGHT LINE .464" TO .860"	285-13-16390	8
7	NUT WASHER 5/8" THREAD JOSLYN	285-08-14674	8