



TITLE:

THREE PHASE UNDERBUILD
ON DUAL PHASE
FIBER ARM

GARLAND
POWER & LIGHT

STANDARD NO.:

OH-1675

DRAWN BY: DATE: APPROVED BY:

GL 10/21/04 CP

REVISED BY: DATE: APPROVED BY:

CONSTRUCTION STANDARD NO. : OH-1675**TITLE: DUAL PHASE FIBER ARM**

REV. DATE: 5/21/2002

PIC. #	DESCRIPTION	IBM NO.	QTY.
1	BOLT DOUBLE ARMING 5/8" X 14"	285-08-21552	1
2	INSULATOR PIN TYPE 15KV	286-42-25100	3
3	BRACKET DUAL-PHASE FIBERGLASS CONT GPB-58H-143 BV	285-21-13810	2
4	BOLT DOUBLE ARMING 5/8" X 16"	285-08-21554	1
5	NUT WASHER 5/8" THREAD JOSLYN	285-08-14674	4
6	BOLT WASHER HEAD 5/8" X 14" W/ WASHER NUT	285-08-96926	1