



DRAWN BY:	DATE:	APPROVED BY: CP
REVISED BY:	DATE:	APPROVED BY:

TITLE:
DISTRIBUTION
POLE BAND DOWN GUY

GARLAND
POWER & LIGHT

STANDARD NO.:
OH-1726

CONSTRUCTION STANDARD NO. : OH-1726**TITLE: POLE BAND, DOWN GUY, 10" ANCHOR W/GUY INSULATOR** **REV. DATE: 5/21/2002**

PIC. #	DESCRIPTION	IBM NO.	QTY.
1	BOLT,1"X8",FOR MAKE UP OF 16000# POLE BAND	285-39-06220	3
2	PREFORM GRIP DEAD END 3/8" GALV	285-22-16102	1
3	DEAD END 3/8" DOWN GUY LONG	285-22-16120	1
4	ROD ANCHOR 1" X 8' TWINEYE	285-03-15050	1
5	ANCHOR 8-WAY 10" CAT. # A322102	285-03-14010	1
6	GUY LINE EXTENSION 1/4" X 3" X 9-1/2"	285-39-06240	2
7	GUARD GUY YELLOW PLASTIC 8' - 8' LENGTH	285-39-35105	1
8	INSULATOR STRAIN EPOXIGLAS 48"X 15/16 FOR GUY WIRES	286-43-13830	1
9	SCREW LAG SQ HEAD 1/2" X 4" GA	285-08-14120	3
10	BAND SECTION	285-39-06215	3