



DRAWN BY: JC	DATE: 3/16/05	APPROVED BY: CP
REVISED BY: JC	DATE: 3/16/05	APPROVED BY:

TITLE:
TRANSMISSION DOWN GUY
SCREW IN ANCHOR

GARLAND
POWER & LIGHT

STANDARD NO.:
OH-1728

CONSTRUCTION STANDARD NO. : OH-1728**TITLE: TRANSMISSION DOWN GUY SCREW IN ANCHOR**

REV. DATE: 3/22/2005

PIC. #	DESCRIPTION	IBM NO.	QTY.
1	BOLT,1"X8",FOR MAKE UP OF 16000# POLE BAND	285-39-06220	4
2	PREFORM GRIP DEAD END 1/2" FANNER	285-22-16119	1
3	CLAMP, 3 BOLT GUY JOSLYN J931	285-13-16520	2
4	COUPLINGS SQ. EXTENSION SHAFTSV 3 1/2 FT. LENGTH, CHANCE # 12655	285-03-15085	2
5	ANCHOR MULTI - HELIX SCREW TYPE SS ON 1-1/2" SHAFT 7' LONG	285-03-15080	1
6	GUY LINE EXTENSION 1/4" X 3" X 9-1/2"	285-39-06240	2
7	GUARD GUY YELLOW PLASTIC 8' - 8' LENGTH	285-39-35105	1
8	INSULATOR STRAIN EPOXIGLAS 48"X 15/16 FOR GUY WIRES	286-43-13830	1
9	SCREW LAG SQ HEAD 1/2" X 4" GA	285-08-14120	4
10	BAND SECTION	285-39-06215	3