



ENGINEER NOTE:
 2-FINGER 285-19-19013
 3-FINGER 285-19-19015

TITLE:
 SINGLE PHASE
 PRIMARY JUNCTION
 CABINET

GARLAND
 POWER & LIGHT
 STANDARD NO.:
 UG-2415

DRAWN BY:	DATE:	APPROVED BY:
REVISED BY:	DATE:	APPROVED BY:

Construction Standard No.

UG-2415

Title: THREE PHASE PRIMARY JUNCTION CABINET

Rev. Date: 11/30/2011

Pic #	Description	WAREHOUSE #	Qty	UOM
1	THREE PHASE JUNCTION CABINET	286-27-30085	1	EA
2	ROD GROUNDING 5/8" X 8'	285-36-15108	1	EA
3	PADLOCK WB-1755 (NOT IN INVENTORY)	N/A	1	EA
4	JUNCTION LOAD BREAK 200 AMP TWO POSITION	285-19-19013	1	EA
5	CLAMP GROUND ROD 5/8"	285-13-16025	1	EA
6	#2 CU BARE HD 7 STR	280-09-21051	6	FT
7	CONNECTOR CRIMPIT COPPER #2 STR TO #2 STR BURNDY YC2C2	285-18-17000	2	EA
8	LUG TRANSFORMER GROUNDING 8 SOL TO 2/O STR	285-49-17325	1	EA
9	ELBOW LOADBREAK #2/O 15KV 200A AL/CU CABLE .220 MIL	285-19-19163	2	EA
10	FIBERGLASS GROUND SLEEVE - SINGLE PHASE	286-27-30055	1	EA
11				
12				
13				
14				
15				
16				
17				
18				
19				
20				
21				
22				
23				
24				
25				
26				
27				
28				

Garland Power & Light



UG-2415