



FOR REMOVAL ONLY

TITLE:

THREE PHASE  
TRANSFORMER  
LIVE FRONT

**GARLAND**  
POWER & LIGHT

STANDARD NO.:

UG-2430L

DRAWN BY:      DATE:      APPROVED BY:  
CP

REVISED BY:      DATE:      APPROVED BY:

**CONSTRUCTION STANDARD NO. : UG-2430L****TITLE: THREE PHASE PADMOUNT XFMR LIVE FRONT  
FOR REMOVAL ONLY**

REV. DATE: 3/22/2005

PIC. #	DESCRIPTION	IBM NO.	QTY.
0	#2 CU BARE HD 7 STR	280-09-21051	15
0	CABLE 5 KV #6 SOLID CU. @ 250 FT. REELS	280-42-50026	20
0	CLAMP GROUND ROD 5/8"	285-13-16025	1
0	CONNECTOR DOUBLE BOLT SWIVEL CAP CU TO CU 500 MCM	285-18-18520	2
0	CONE #2 & 2/0 STRESS 15 KV MOLDED RUBBER	285-19-19130	6
0	LUG TRANSFORMER GROUNDING 8 SOL TO 2/0 STR	285-49-17325	2
0	LUG TERMINAL 2/0 STRAND ALUM	285-49-17572	6
0		285-49-17583	6
0	#2 HOMAC LUG - AL	285-54-17537	1
0	ARRESTOR LIGHTING MOV TYPE 10KV, POLYMER	286-04-10010	6
0	FAULT INDICATOR LOAD TRACKER PADMOUNT - SINGLE PHASE	286-30-10345	6
0	BOLT HEX HD 1/2" X 1" STN/STL	320-09-11256	12
0	BOLT HEX HD 1/2" X 1-1/2" STN/STL	320-09-11258	18
0	NUT HEX 1/2" STN/STL	320-09-13051	30
0	WASHER BELLEVILLE 9/16" STN/ST	320-09-30130	12

0	TAPE ELEC INSUL SILICONE RUBBER	835-27-11250	2
---	---------------------------------	--------------	---