



REF. DWG 310A BLUE BOOK

TITLE:  
 1' x 6'-6" x 8'  
 REBAR DETAIL FOR  
 CONCRETE TRANSFORMER  
 PAD WHEN CUSTOMERS  
 SECONDARY DOES NOT  
 EXCEED 16 CONDUCTORS

**GARLAND**  
 POWER & LIGHT

STANDARD NO.:  
 UG-2510-2

DRAWN BY:	DATE:	APPROVED BY:
		CP
REVISED BY:	DATE:	APPROVED BY:
GL	7/7/04	

**CONSTRUCTION STANDARD NO. : UG-2510**

**TITLE: XFMR PAD 6'6"X8' ONE 3 PHASE XFMR**

REV. DATE: 3/30/2005

PIC. #	DESCRIPTION	IBM NO.	QTY.
1	ROD GROUNDING 5/8" X 8'	285-36-15108	2
2	REBAR 5/8" - 20' LENGTH	570-80-12230	4