



C	#2 - 4"
D	#2/0 - 4"
W	WOOD
F	FIBER

RIGID ELBOW AND PVC CONDUIT BY CUSTOMER

GROUND ROD TO BE DRIVEN IN BELOW GROUND LEVEL AT LEAST 12" FROM POLE

* INSTALL GROUNDING CLAMP 6" BELOW TOP OF RIGID CONDUIT

DRAWN BY: GL	DATE: 12/8/04	APPROVED BY: CP
REVISED BY:	DATE:	APPROVED BY:

TITLE:
**DUAL PHASE RISER
 ON FIBER/WOOD**
 REMOVAL OR TRANSFER
 ONLY

GARLAND
 POWER & LIGHT

STANDARD NO.:
 UG-2720