



ENGINEERING NOTE:  
 NEW CONSTRUCTION  
 ADD PEDESTAL & #6  
 SPLIT BOLT

INSTALL FUSE KIT  
 IN PEDESTAL

FILL WITH LOCAL SOIL  
 AND TRAMP DOWN

GRADE  
 4'  
 ENTRANCE HOLE  
 12" DIA. HOLE MAX.

TITLE:

100W HPS  
 POST TOP LUMINAIRE

**GARLAND**  
 POWER & LIGHT

DRAWN BY:	DATE:	APPROVED BY:
		CP

REVISED BY:	DATE:	APPROVED BY:
GL	1/13/05	

STANDARD NO.:  
 UG-2910

**CONSTRUCTION STANDARD NO. : UG-2910****TITLE: POST TOP LUMINAIR 100W HPS**

REV. DATE: 5/21/2002

PIC. #	DESCRIPTION	IBM NO.	QTY.
1	CONTROLLER PHOTOELECTRIC 1000	528-65-12070	1
2	LAMP IGNITRON 100 WATTS HPS	528-40-12110	1
3	LUMINAIRE 100 WATT 5-WAY H.P.S	528-50-17200	1
4	POLES ST LIGHT FIBERGLASS 24 FT FOR POST TOP LUMINAIRE	528-66-75100	1
5	FUSE, NON-RENEWABLE, 8 AMP. 600 VOLT	285-32-21500	1
6	CONNECTOR FUSED KIT	285-32-60100	1