



NOTE:

CONDUIT BENDS TO BE A MINIMUM OF 48" DEEP  
AND MUST BE INSPECTED BY G.P. & L. BEFORE COVERED

TITLE:

7' 4" 2 TRANSFORMER 10  
OPEN WYE ("Y") DELTA PAD

**GARLAND**  
POWER & LIGHT

APPROVED:

STANDARD NO.:

REF - 33

|          |       |           |
|----------|-------|-----------|
| REVISED: | DATE: | APPROVED: |
|          |       | CP        |