



NOTES:

1. BACK AND SIDES SHOULD HAVE A MINIMUM OF FT. CLEARANCE.
2. FRONT SHOULD HAVE A MINIMUM OF 10 FT. CLEARANCE.

TITLE:

**TRANSFORMER PAD
WITH CONNECTION CUBICLE
AND 2 1Ø TRANSFORMERS**

GARLAND

POWER & LIGHT

APPROVED:

STANDARD NO.:

REF - 35

REVISED:	DATE:	APPROVED:
		CP