



CUSTOMER TO FURNISH AND INSTALL

- ① SERVICE ENTRANCE CONDUCTOR
- ② CONDUIT AND WEATHERHEAD

G.P. & L. TO FURNISH, CUSTOMER TO INSTALL

- ③ METER BASE (SINGLE OR THREE PHASE)
200 AMP. AND BELOW

G.P. & L. TO FURNISH AND INSTALL

- ④ METER (200 AMP. AND BELOW)
- ⑤ SERVICE CABLE AND CONNECT
- ⑥ CONDUIT AND WEATHERHEAD
- ⑦ PAD - MOUNT TRANSFORMER

TITLE:

TYPICAL UNDERGROUND SERVICE,
MULTI-METER ARRANGEMENT WITH
GROUPED WEATHERHEAD
(200 AMP. AND BELOW)

GARLAND

POWER & LIGHT
APPROVED:

STANDARD NO.:

REF - 40

REVISED: DATE: APPROVED:
CP